

**Reclamation District 900
Unit 117, LMA Unit 1 LM 3.79
2026-002**

**Contract Documents for
Levee Slope Rehabilitation Project**

ADDENDUM NO. 3

WORK ORDER NUMBER: 2026-002

Prepared for:

Reclamation District 900

October 19, 2026

Approved:



Blake Johnson
General Manager

October 19, 2026

Date



Kyle Sanchez, RCE 93438

October 19, 2026

Date

RECLAMATION DISTRICT 900

1204 E Street (District Engineer Office)
Marysville, California 95901

ADDENDUM NO. 3

TO

Levee Slope Rehabilitation Project
Work Order Number 2026-002

THIS ADDENDUM shall be considered as part of the Contract Documents and shall be signed and attached to the volume of proposal documents, which must be submitted with the bid.

The following revision is to be made to the Contract Documents:

SUMMARIZED QUESTIONS FROM PROSPECTIVE BIDDERS

1. **Question:** Please confirm whether the establishment period in Section 32 92 19, an 85 percent stand maintained through May 1 of the following year, applies to Item B8, Hydroseeding.

Response: Yes, hydroseeding shall require an 85 percent stand maintained through May 1 of the following year.

2. **Question:** Please provide the species, size, quantity or spacing, anchorage and planting method for Item B7, Willow Bundles (Sheet D-1), including any soil backfill or embedment needed for the bundles to root within the rock, and whether survival is required.

Response: The vertical bundle shall be between 3 and 18 inches and should average about 3-5 stems. They should be placed per Caltrans standard method within the rock. A small amount of soil backfill will be placed on top and can be sourced from the surrounding soil. There is no timeframe requirement on the survival.

I acknowledge receipt of Addendum Number 3 to the subject project and accept all conditions contained herein. The information and revisions presented in this Addendum has been considered in preparation of my proposal.

Bidder: _____

Signature: _____ Date: _____

Title: _____